



America

CERTIFICATE

No. U10U 119746 0004 Rev. 00

Holder of Certificate: **ATS Corporation**
1 Natura Way
Cambridge ON N3C 0A4
CANADA

Certification Mark:



Product: **Industrial Control Systems and Components
Automation Conveyor Control Panel**

Tested according to: UL 508A:2018/R:2020-08

This product was voluntarily tested to the relevant safety requirements referenced on this certificate. It can be marked with the certification mark above. The mark must not be altered in any way. The certificate holder shall not transfer this certificate to third parties. This product certification system operated by TÜV SÜD America Inc. most closely resembles system 3 as defined in ISO/IEC 17067. Certification is based on the TÜV SÜD "Testing and Certification Regulations".

Test report no.: 7169010688-001

Date, 2023-05-03

(Steven Lee)



America

CERTIFICATE

No. U10U 119746 0004 Rev. 00

Model(s): CP-5037443-NA-I3

Parameters:

Rated input voltage: 208/120 VAC 3ph+N WYE

Rated input frequency: 50/60 Hz

Rated input current: FLA 55 A, SCCR 5 kA

Protection Class: I