ZERTIFIKAT ◆ 认证证书 ◆ CERTIFICATE ◆ 認証書 ◆ CERTIFICATO ◆ 인증서 ◆ CERTIFICADO

C E R T I F I C A T E

No. U10U 119746 0010 Rev. 00

Holder of Certificate: **ATS Corporation**
1 Natura Way
Cambridge ON N3C 0A4
CANADA

Certification Mark:

Product: **Industrial Control Systems and Components**
Automation Conveyor Control Panel

Tested according to: UL 508A:2018/R:2022-07

This product was voluntarily tested to the relevant safety requirements referenced on this certificate. It can be marked with the certification mark above. The mark must not be altered in any way. The certificate holder shall not transfer this certificate to third parties. This product certification system operated by TÜV SÜD America Inc. most closely resembles system 3 as defined in ISO/IEC 17067. Certification is based on the TÜV SÜD "Testing, Certification, Validation and Verification Regulations (TCVVR)".

Test report no.: 7169015229B-100

Date, 2026-10-06

(Peter Keith)

TÜV SÜD America, Inc. • 401 Edgewater Place Suite #500 • Wakefield • MA 01880 • USA

ZERTIFIKAT ◆ 认证证书 ◆ CERTIFICATE ◆ 認証書 ◆ CERTIFICATO ◆ 인증서 ◆ CERTIFICADO

C E R T I F I C A T E

No. U10U 119746 0010 Rev. 00

Model(s): 10241202-NA-SI-1PH, 10241202-EU-SI-1PH, 10241202-NA-1PH, 10241202-EU-1PH, 10241202-SI, 10241202-AD

Brand Name(s): **SuperTrak Conveyance**

Parameters:

10241202-NA-SI-1PH & 10241202-NA-1PH:
Rated Voltage: 208/120 VAC 3Ph+N WYE
Rated Frequency: 50/60 Hz
Rated Current: FLA 36 A, SCCR 5kA
Protection Class: I

10241202-EU-SI-1PH & 10241202-EU-1PH:
Rated Voltage: 400/230 VAC 3Ph+N WYE
Rated Frequency: 50/60 Hz
Rated Current: FLA 36 A, SCCR 5kA
Protection Class: I

10241202-xx:
Rated Voltage: 24 VDC
Rated Current: FLA 10 A
Protection Class: I

TÜV SÜD America, Inc. • 401 Edgewater Place Suite #500 • Wakefield • MA 01880 • USA